

NOTE:

- 1. ALL DIMENSIONS IN MILLIMETRES.
- ALL WORKS ON EXISTING WATER MAIN TO BE CARRIED OUT TO THE SATISFACTION OF COUNCIL
- 3. WHERE SUFFICIENT COVER EXISTS DETAIL MAY BE INVERTED TO ALLOW DIVERSION OVER THE SERVICE.
- AN ALTERNATIVE OF SUITABLY RATED CEMENT LINED STEEL OR DUCTILE IRON MAY BE USED FOR DIVERSION MATERIAL.
- 5. OPTIONAL SOCKET ADAPTOR OR MECHANICAL CONNECTORS.

D.I. WATERMAIN DIVERSION (ALTERNATIVE)



STANDARD DETAILS	Drawn	Designed	
	J. GOODMAN	KCDC	
	Approved	Revision Date	
MAINS AND RIDER MAINS WATERMAIN DIVERSION	B. MAGUIRE	OCTOBER 2020	
	Scale	Drawing No.	Revision
	NOT TO SCALE	HDC-WS-010	R0

20 MPa CONCRETE THRUST BLOCKS.

CONCRETE TO BE KEPT CLEAR OF JOINTS